



File E125840

Vol 2

Issued 02/08/1996
Revised 03/14/2002

FOLLOW-UP SERVICE PROCEDURE
(TYPE L)

POWER LIMITED CIRCUIT CABLE
(QPT2)

Manufacturer: HOSIWELL TECHNOLOGY CO LTD
(372077-001) 79 MOO 5
T BANGSAMUK
A BANGPAKONG
CHACHOENGSAO 24130 THAILAND

Applicant: HOSIWELL ENTERPRISE CO LTD
(484691-001) 1ST FL
23 LANE 140 KUN YANG ST
NAN KUANG
TAIPEI TAIWAN

Listee: SAME AS APPLICANT
(484691-001)

This Procedure authorizes the above Manufacturer to use the marking specified by Underwriters Laboratories Inc. only on products covered by this Procedure, in accordance with the applicable Follow-Up Service Agreement.

The prescribed Mark or Marking shall be used only at the above manufacturing location on such products which comply with this Procedure and any other applicable requirements.

The Procedure contains information for the use of the above named Manufacturer and representatives of Underwriters Laboratories Inc. and is not to be used for any other purpose. It is lent to the Manufacturer with the understanding that it is not to be copied, either wholly or in part, and that it will be returned to Underwriters Laboratories Inc. upon request.

This PROCEDURE, and any subsequent revisions, is the property of UNDERWRITERS LABORATORIES INC. and is not transferable.

UNDERWRITERS LABORATORIES INC.

A handwritten signature in black ink, appearing to read 'A.W. Schaefer'.

A.W. Schaefer
Vice President and General Manager
Laboratory Management and Operations

D E S C R I P T I O N

PRODUCT COVERED:

Power-Limited Circuit Cable, Types CL2X, CL2, CL2R, CL3X, CL3, CL3R, rated 60 or 75°C.

ENGINEERING CONSIDERATIONS (NOT FOR UL REPRESENTATIVE'S USE):

Evaluated in accordance with the latest issue of the Standard for Power-Limited Circuit Cables, UL 13.

CONSTRUCTION:

Assembly - Multiconductor jacketed cable with non-integral jacket in accordance with the Standards.

Conductor - AWG size in accordance with Table 1 and the Standard.

Insulation - HDFRPE, thickness in accordance with Tables 1a, 1b, and the Standard.

Shields - Optional metallic shields in accordance with the Standard.

Jacket - PVC, thickness in accordance with Table 2 and the Standard.

Markings - Required Surface and tag markings in accordance with the Standard, Section General, and the FUII pages.